WEST BENGAL STATE ELECTRICITY TRANSMISSION COMPANYLTD.

(A Govt. of West Bengal Enterprise)
CIN : U40101WB2007SGC113474
OFFICE OF THE CHIEF ENGINEER (O& M) – II
VIDYUT BHAVAN:10th FLOOR:D BLOCK,
SALT LAKE CITY:KOLKATA :- 700091,
TELE PHONE /FAX NO. (033) 2359-1901.

Memo No.: CE/ (O&M) – I/TENDER/TR. OIL FILTRATION/RATE CONTRACT/2020-22/1206 DATED: - 15/2/2020

NOTICE

Sub : Reply of Pre-bid queries for the work of "BIENNIAL RATE CONTRACT FOR INSTALLATION OF NEW TRANSFORMERS AS WELL AS OVERHAULING AND RECONDITIONING OF VARIOUS POWER TRANSFORMER OF CAPACITY 12.5 MVA TO 315 MVA AT DIFFERENT EHV SUB-STATIONS OF WBSETCL".

Ref : NI e-T No: CE/ (O&M) – I/TENDER/ TR. OIL FILTRATION/RATE CONTRACT/2020-22/37, DATED 03.02.2020

With reference to above and discussion with the bidders in the Pre-Bid Meeting held on **13.02.2020**, necessary clarification, confirmation and PRE-BID COMMENTS is enclosed herewith for further necessary action and these shall be considered as an integral part of the NIT.

All other terms and conditions as stated in the NIT will remain unchanged.

Enclo: Reply of Pre-bid queries.

Yours faithfully,

14/02/20

(G. K. De)
Chief Engineer: (O&M) – I

Pre Bid Comments on 13.02.2020 in reference to NIT- CE/ (O&M) – I/TENDER/ TR. OIL FILTRATION/RATE CONTRACT/2020-22/37, DATED 03.02.2020

SL No	Clause / ITB No	Clarification Sought on	Clarification by WBSETCL
1	Section (I)- NIT Sub-Section- 5.0 Technical (A)	**A. For transformers upto 400/220 KV 315 MVA category :** Successful Erection & Commissioning of 315 MVA, 400/220 kV or above rated Transformers **FOR minimum 3 nos. OR** Successful Overhauling /Maintenance which must include dismantling & re-fitting of HV/LV Bushings, Radiator banks, Vacuum –cum-hot oil filtration, etc., of 315MVA, 400/220 kV or above rated Transformers **FOR minimum 3 nos. OR** Successful Erection & Commissioning & Successful Overhauling Maintenance taken together which must include dismantling & re-fitting of HV/LV Bushings, Radiator banks, Vacuum –cum-hot oil filtration, etc. of 315MVA ,400/220 kV or above rated **Transformers FOR minimum 3 nos.**	**A. For transformers upto 400/220 KV 315 MVA category :** Successful Erection & Commissioning of 315 MVA, 400/220 kV or above rated Transformers **FOR minimum 3 nos. OR** Successful Overhauling /Maintenance which must include dismantling & re-fitting of HV/LV Bushings, Radiator banks, Vacuum –cum-hot oil filtration, etc., of 315MVA, 400/220 kV or above rated Transformers **FOR minimum 3 nos. OR** Successful Erection & Commissioning & Successful Overhauling Maintenance taken together which must include dismantling & re-fitting of HV/LV Bushings, Radiator banks, Vacuum –cum-hot oil filtration, etc. of 315MVA ,400/220 kV or above rated **Transformers FOR minimum 3 nos. within last 05 (Five) Financial years from the date of issuance of N.I.T.**
2	Section (I)- NIT Sub-Section- 5.0 Technical (B)	**B. For Transformers upto 220/132 KV 160 MVA category :** Successful Erection & Commissioning of 100MVA, 220/132 kV or above rated Transformers **FOR minimum 3 nos. OR** Successful Overhauling /Maintenance which must include dismantling & re-fitting of HV/LV Bushings, Radiator banks, Vacuum –cum-hot oil filtration, etc., of 100MVA, 220/132kV or above rated Transformers **FOR minimum 3 nos. OR** Successful Erection & Commissioning & Successful Overhauling Maintenance taken together which must include dismantling & re-fitting of HV/LV Bushings, Radiator banks, Vacuum –cum-hot oil filtration, etc. of 100MVA, 220/132kV or above rated **Transformers FOR minimum 3 nos.**	**B. For Transformers upto 220/132 KV 160 MVA category :** Successful Erection & Commissioning of 100MVA, 220/132 kV or above rated Transformers **FOR minimum 3 nos. OR** Successful Overhauling /Maintenance which must include dismantling & re-fitting of HV/LV Bushings, Radiator banks, Vacuum –cum-hot oil filtration, etc., of 100MVA, 220/132kV or above rated Transformers **FOR minimum 3 nos. OR** Successful Erection & Commissioning & Successful Overhauling Maintenance taken together which must include dismantling & re-fitting of HV/LV Bushings, Radiator banks, Vacuum –cum-hot oil filtration, etc. of 100MVA, 220/132kV or above rated **Transformers FOR minimum 3 nos. within last 05 (Five) Financial years from the date of issuance of N.I.T.**

14/02/2020

Pre Bid Comments on 13.02.2020 in reference to NIT- CE/ (O&M) – I/TENDER/ TR. OIL FILTRATION/RATE CONTRACT/2020-22/37, DATED 03.02.2020

3	Section (I)- NIT Sub-Section- 5.0 Technical (C)	**C. For Transformers upto 132/33 KV 50 MVA category :** Successful Erection & Commissioning of 12.5MVA, 132/33kV or above rated Transformers **FOR minimum 3 nos. OR** Successful Overhauling /Maintenance which must include dismantling & re-fitting of HV/LV Bushings, Radiator banks, Vacuum –cum-hot oil filtration, etc., of 12.5MVA, 132/33kV or above rated Transformers **FOR minimum 3 nos. OR** Successful Erection & Commissioning & Successful Overhauling Maintenance taken together which must include dismantling & re-fitting of HV/LV Bushings, Radiator banks, Vacuum –cum-hot oil filtration, etc. of 12.5MVA,132/33kV or above rated **Transformers FOR minimum 3 nos.**	**C. For Transformers upto 132/33 KV 50 MVA category :** Successful Erection & Commissioning of 12.5MVA, 132/33kV or above rated Transformers **FOR minimum 3 nos. OR** Successful Overhauling /Maintenance which must include dismantling & re-fitting of HV/LV Bushings, Radiator banks, Vacuum –cum-hot oil filtration, etc., of 12.5MVA, 132/33kV or above rated Transformers **FOR minimum 3 nos. OR** Successful Erection & Commissioning & Successful Overhauling Maintenance taken together which must include dismantling & re-fitting of HV/LV Bushings, Radiator banks, Vacuum –cum-hot oil filtration, etc. of 12.5MVA,132/33kV or above rated **Transformers FOR minimum 3 nos. within last 05 (Five) Financial years from the date of issuance of N.I.T.**
4	Section (IV)- Terms & Condition Sub-Section- 5.0	'Gang Mobilization' charges would be admissible to the agency only when the agency would be engaged exclusively for Tap-Changer overhauling works & Transformer bushing replacement works and will be decided by the WBSETCL.	'Gang Mobilization' charges would be admissible to the agency only when the agency would be engaged exclusively for Tap-Changer overhauling works , Transformer bushing replacement works OR **Vaccum-Cum-Hot Filtration of the entire Transformer oil at a steady oil tempeture (Where no other associated work are involved) and will be decided by the WBSETCL.**

14/02/2020